



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/80317

Date: 10-07-2023

**From:**  
Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

**To: AMRITA VIDYALAYAM**  
C2/24, NEW BUDGE BUDGE TRUNK ROAD, WARD NO.-11, UNDER MAHESHTALA MUNICIPALITY, P.S.-  
MAHESHTALA, P.O.- SARKARPOOL, KOLKATA-700143.

**Sub: Renewal of Fire Safety Certificate for the existing occupancy comprising of G+II and G+III storied school building under group Educational Building in the name of 'Amrita Vidyalayam' at the premises No. C2/24, New Budge Budge Trunk Road, Ward No 11, P.O. Sarkarpool, P.S. Maheshtala under Maheshtala Municipality, Kolkata-700143.**

This is in reference to your application no. 0125191231200192 dated 03-06-2023 regarding the Renewal of Fire Safety Certificate for the existing occupancy comprising of G+II and G+III storied school building under group Educational Building in the name of 'Amrita Vidyalayam' at the premises No. C2/24, New Budge Budge Trunk Road, Ward No 11, P.O. Sarkarpool, P.S. Maheshtala under Maheshtala Municipality, Kolkata-700143.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

CONDITION : JOCKEY PUMP TO BE PROVIDED FOR MAINTING PRESSURIZED WET RISER ROUND THE CLOCK.  
1.All the Fire Safety measures provided in the building must be kept in good working condition all the time to ensure fire & life safety of the building.